



BULGARKONTROLA S.A.

**CARGO & DAMAGE SURVEYS, LABORATORY ANALYSES,
CONFORMITY ASSESSMENT & TECHNICAL INSPECTIONS,
MANAGEMENT SYSTEMS, ORGANIC CERTIFICATION**

Head office: 23, Sitnyakovo Blvd., 1505 Sofia, Bulgaria
Emergency mobile: +359 889 400 400, Tel.: +359 2 989 4070, Fax: +359 2 988 2354
E-mail: sales@bulgarkontrola.bg, cert@bulgarkontrola.bg

CERTIFICATE OF CONFORMITY

14 – НУРВСУСРВ – 3538

Issued pursuant to Art. 14, par.1 and par. 2 of the Regulation № РД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

WELDABLE REINFORCING STEEL class B 500 B of bars

used for the reinforcement of concrete with nominal diameter

and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

placed on the market by

ÇOLAKOĞLU METALURJIA A.Ş

**Rüzgarlıbahçe Mah. Çam Pınarı Sk. No:1 İç Kapı No:16 Beykoz
İstanbul/Turkey**

manufactured by

ÇOLAKOĞLU METALURJIA A.Ş

**Dilovasi Organize Sanayi Bölgesi, Göksu Cad., 41455
Dilovaci-Kocaeli, Turkey**

This certificate certifies that the product has been evaluated
and meets national requirements set out in


BDS 9252: 2007

*and item 1.1 of Annex 3 to item 2 of Order № RD-02-14-1329 from 03.12.2015
of the Minister of Regional Development and Public Works,
amendment and addition by Order № RD-02-14-590 from 05.07.2017*

The Certificate was issued on **10/03/2021**, cancel the Certificate **14-НУРВСУСРВ-3095** from **08/03/2018** and remains valid until **09/03/2024**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

**Place: Sofia
Date: 10/03/2021**

Director of "Conformity Assessment" Dept. /T. Lyubenova/




BULGARKONTROLA S.A.– Sofia with identification number 14 of register Ministry of Regional Development and Public Works
Permit № ПОССП-14 on 15.09.2016 , issued by Ministry of Regional Development and Public Works



1. Nominal diameter:

- Bars with nominal diameter №: 8/ 8,5/ 9/ 9,5/ 10/ 11/ 12/ 14/ 16/ 18/ 20/ 22/ 25/ 28/ 32/ 36/ 40

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare border level
Yield strength, R_e	min 500 MPa According tabl. № 4 of BDS 9252:2007
Tensile strength, R_m	min 550 MPa According tabl. № 4 of BDS 9252:2007
R_m / R_e	min 1,08 According tabl. № 4 of BDS 9252:2007
Elongation Agt, %	min 5 % According tabl. № 4 of BDS 9252:2007
Bending at 180°	without cracks According tabl. № 4 of BDS 9252:2007
Bending/rebinding, at 90°	without cracks According tabl. № 4 of BDS 9252:2007
Linear mass, kg / m	0,395÷9,856 According tabl. № 1 of BDS 9252:2007
Cross-sectional area A_n , mm	50,3÷1256,6 According tabl. № 1 of BDS 9252:2007
Relative area of the ribs, f_r	6 < d ≤ 12 mm: f_r min.0,040 d > 12 mm: f_r min.0,056 According tabl. № 2 of BDS 9252:2007
Profile	 <p>According to fig.2 of BDS 9252:2007</p>
Fatigue strange*, n number of cycles N	N.R.
Chemical composition Weldability (carbon equivalent), C_{eq}	max. 0,50 -for the heat max. 0,52 – for the product According tabl. № 3 of BDS 9252:2007

* Where required

Place: Sofia
Date: 10/03/2021

Director of "Conformity Assessment" Dept.

/T. Lyubenova/

